



CITY OF DULUTH
PURCHASING DIVISION
Room 100 City Hall
411 West First Street
Duluth, Minnesota 55802-1199
218/730-5340 218/730-5922 FAX
purchasing@duluthmn.gov

Addendum #2
File # 15-0663 and 15-0665
DEMOLITION AND UTILITY CUTOFFS

This addendum serves to notify all bidders of the following changes to the solicitation documents:

- 1) 57th Ave W was rebuilt last year, and has a new sewer main and services stubbed out. For the 5702 W 8th Street demo, the contractor needs to dig in the boulevard (between curb and sidewalk) to cap the sewer, and the building has two services – cap in two locations. Does not need to dig in the street.

Please acknowledge receipt of this Addendum by signing, dating, and submitting a copy with your bid/proposal. Thank you.

Signature _____

Date _____

Posted November 24, 2015.